



File No. DM/0289/2020/JA-1(VIG)HO
Directorate of Enforcement, Vigilance & Disaster Management
Greater Hyderabad Municipal Corporation

From
The Director,
Enforcement, Vigilance &
Disaster Management,
GHMC, Hyderabad.

To
The Management,
Sri Chaitanya High School,
Sy. No. A-17/4,
Nacharam, Medchal District.

Rc. No. DM/0289/2020, Dated: 14.12.2020

Sir,

Sub: - Directorate of EV&DM - GHMC - Existing Non High-Rise Educational Building consisting Stilt + 4 upper floors - Sri Chaitanya High School, Nacharam - Renewal of Fire No Objection Certificate - Issued - Regarding.

- Ref: - 1. Proceeding Rc. No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
2. Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt. 29.06.2018 of the Commissioner, GHMC.
3. Fire NOC Issued Vide Rc. No. DM/0353/2019, Dated: 27.04.2019.
4. Application of the Management, Dated: 02-09-2020.
5. E-office Computer No. 249759 & file No. DM/0289/2020/Director EV&DM, GHMC.
6. Inspection report, Dated: 14.12.2020.

Vide reference 4th cited, the management of Sri Chaitanya High School has requested for Renewal of Fire No Objection Certificate to the Existing Non High-Rise Educational Building consisting Stilt + 4 upper floors in Sy. No. A-17/4, Nacharam, Medchal District. Vide reference 6th cited, the team has inspected & submitted the following report.

2. Particulars of the Building:

a)	Name & Address of the building	Sri Chaitanya High School, Sy. No. A-17/4, Nacharam, Medchal District
b)	Plot Area/Height	9270.30 Sq. Meters/14.95 Meters
c)	No of floors	Stilt + 4 upper floors
d)	Name of the Owner & Mobile no.	The Headmaster, 9000941153

3. Floor wise details:

Sl. No.	Floor	Area in Sq. Meters	Type of Occupancy	Max Occupant Load Asper Floor area
1	Stilt Floor	1200.61	Parking	-
2	First Floor	1200.61	Educational	300
3	Second Floor	1200.61	Educational	300
4	Third Floor	1200.61	Educational	300
5	Fourth Floor	1200.61	Educational	300
	Total	6003.05	-	-

:2:

4. Open Spaces All Round Building:

Sl. No.	Directions	Required as per NBC	Provided	Deficit
1	FRONT (East)	6.00 Meters	18.50 Meters	Nil
2	SIDE I (North)	6.00 Meters	6.00 Meters	Nil
3	SIDE II (South)	6.00 Meters	6.00 Meters	Nil
4	REAR (West)	6.00 Meters	6.10 Meters	Nil

5. Means of escape:

Sl. No.	Means of escape required as per NBC-2016			Provided		Deficit
	Staircases	Nos.	Width	Nos.	Width	
1	Internal	01	1.50 Meters	01	1.50 Meters	Nil
		-	-	01	1.20 Meters	
2	External	01	1.50 Meters	01	1.50 Meters	Nil

6. The Minimum Fire Safety Installations required & provided by the builder as per the Table 7 of Part-4 of N.B.C of India 2016:

Sl. No.	Fire Safety Installations	Required	Provided	Deficit
1	Fire Extinguishers	30 Nos.	30 Nos.	Nil
2	First Aid Hose Reel 2 Nos. in each floor	10 Nos.	10 Nos.	Nil
3	Down Comer	NR	02 Nos.	Nil
4	Manually operated Electronic Fire Alarm Systems	NR	10 Nos.	Nil
5	Terrace Tank over Respective Tower Terrace	10,000 Liters	10,000 Liters	Nil
6	At the Terrace Tank level with Minimum Pressure of 3.5 Kg/Cm ²	Booster Pump 450 LPM	Booster Pump 450 LPM	Nil

Terms & Conditions: -

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.
2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.
3. No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
4. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.

::3::

5. Every room with a capacity of 45 students (for educational building) shall be maintained obstruction free minimum two doorways.
6. Every vertical opening between at the floors shall be suitably enclosed or protected, with ventilation System by ducts and Balconies.
7. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
8. Fresh NOC would be required for any change in occupancy or additions/ alterations in the building structure as per NBC of India and building bye/laws.
9. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
10. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
11. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
12. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
13. This Order will be without any prejudice to take action against the Unauthorized construction if any made.
14. Fire NOC should be displayed at a conspicuous place.
15. This Renewal of Fire No Objection Certificate for Existing Non High-Rise Educational Building is valid for one year from the date of issue and it is the responsibility of the builder/occupier to apply for Renewal of Fire NOC two months before expiry of this Fire NOC.

In view of the above, the Renewal of Fire No Objection Certificate is issued to the management of Sri Chaitanya High School, Sy. No. A-17/4, Nacharam, Medchal District, subject to strict provisions of the above Fire & Life Safety systems.

Signature valid

DIRECTOR,
EV & DM, GHMC

Digitally signed by VISWAJIT
KAMPATI IPS
Date: 2020.12.18 15:30:18 IST
Reason: Approved